

Technical Bulletin Ref: DOTB002		Publication Date: 01/04/2026
Author: Development Operation	Approver: TSA (MgF)	
For further information contact: developmentoperations@scottishwater.co.uk		

Brief Description

Due to a lack of clear direction regarding Wastewater Pumping Station access requirements, this Technical Bulletin is to provide further clarity to the following points in Sewers for Scotland 4.

- 2.26.2 Site Access
- 2.26.3 Site Layout
- 2.26.5 Storage on Site
- Figure 27

Clarification and Changes to be applied to existing clauses within SfSv4 Pumping Station – Tanker Access Requirements

Dedicated Access (2.26.2(4))

- A dedicated access route must be provided for 32-tonne tankers.

WWPS Located Near a Public Road (2.26.2)

- Off-street parking for the tanker must be provided.
- Reversing may be permitted for parking purposes only; this will be considered on a site-by-site basis. RAMS may be requested.
- The tanker must not be required to reverse more than the distance necessary to park in a straight line.

WWPS Located Away from a Public Road (2.26.3)

- If the WWPS is located away from a public road the tanker must be able to enter and exit the access area head-on (no reversing).

Swept Path Analysis (2.26.2)

- A full swept path analysis for the 32-tonne tanker must be submitted to demonstrate all manoeuvres associated with access, parking, and egress.

Surface Finishes (2.26.2)

- Access tracks must be constructed using a cellular paving system designed for high-load applications (up to 40 tonnes) while allowing for vegetation growth and water permeability.
- Granular stone finishes and whin dust are not permitted.

Emergency Storage (2.26.5)

- No WWPS assets are to be located beneath any SUDS access track.

Tanker Hard Standing (Figure 27)

- The tanker hard standing area must:
 - Be of non-porous construction.
 - Not form part of the SUDS access track.

Use of Public Roads and Private Drives (2.26.2)

- Public roads and private drives are not to be used as part of the tanker access route.
- Tankers are not permitted to park on the roadside to access any pumping station.

Applications effected

- ✓ All new Applications received after the date of this Bulletin
- Applications awaiting Technical Approval and all new submissions
- Applications with Technical Approval but not on site
- All Developments including those on site *e.g. H&S or WQ issues*

Circulation List

- ✓ Dev Serv Team
- ✓ Housing Developers
- ✓ Design Associates
- ✓ SLO's